



**COUNTY OF LOS ANGELES  
FIRE DEPARTMENT  
FIRE PREVENTION DIVISION**

**LIQUID- OR GAS-FUELED VEHICLES OR EQUIPMENT IN  
ASSEMBLY BUILDINGS PERMIT REQUIREMENTS**

---

Appendix Chapter 1, section 105.6.26 of the Los Angeles County Fire Code states that permits required by the Fire Code shall be obtained from the fire code official. An operational permit is required to display, operate or demonstrate liquid- or gas-fueled vehicles or equipment in assembly buildings.

**Vehicles.** Liquid- or gas-fueled vehicles, boats or other motor craft shall not be located indoors except as follows: Chapter 3 Sec.3.14.4

1. Batteries are disconnected.
2. Fuel in fuel tanks does not exceed one-quarter tank or 5 gallons (19 L) (whichever is least).
3. Fuel tanks and fill openings are closed and sealed to prevent tampering.
4. Vehicles, boats or other motor craft equipment are not fueled or defueled within the building.

Vehicles and equipment used for display within tents, canopies or membrane structures shall be in accordance with chapter 24 Sections 2404.18.1 through 2404.18.5.3.

Additional  
Requirements \_\_\_\_\_  
Rev.01/09