



COUNTY OF LOS ANGELES FIRE DEPARTMENT

FIRE PREVENTION DIVISION

BONFIRE OR RUBBISH FIRE PERMIT REQUIREMENTS

Appendix Chapter 1, section 105.6.3.2 of the Los Angeles County Fire Code states that permits required by the Fire Code shall be obtained from the fire code official. An operational permit is required to kindle, maintain, authorize kindling, maintenance of bonfires and rubbish fires. See Chapter 3. operate a place of assembly. Additional requirements may be applicable.

Bonfires or rubbish shall comply with all the requirements of section 307 & 308 of this code

A permit shall be obtained from the fire code official in accordance with Appendix Chapter 1, Section 105.6 prior to kindling a fire for recognized silvicultural or range or wildlife management practices, prevention or control of disease or pests, or a bonfire. Application for such approval shall only be presented by and permits issued to the owner of the land upon which the fire is to be kindled.

Bonfires. A bonfire shall not be conducted within 50 feet (15 240 mm) of a structure or combustible material unless the fire is contained in a barbecue pit. Conditions which could cause a fire to spread within 50 feet (15 240 mm) of a structure shall be eliminated prior to ignition.

Attendance. Open burning; bonfires or recreational fires shall be constantly attended until the fire is extinguished. A minimum of one portable fire extinguisher complying with Section 906 with a minimum 4-A rating or other pproved on-site fire-extinguishing equipment, such as dirt, sand, water Barrel, garden hose or water truck, shall be available for immediate utilization.

Additional
Requirements _____.

Rev. 01/09