



**COUNTY OF LOS ANGELES
FIRE DEPARTMENT
FIRE PREVENTION DIVISION**

PRIVATE FIRE HYDRANTS PERMIT REQUIREMENTS

Appendix Chapter 1, section 105.6.28 of the Los Angeles County Fire Code states that permits required by the Fire Code shall be obtained from the fire code official. An operational permit is required for the removal from service, use or operation of private fire hydrants.

Exception: A permit is not required for private industry with trained maintenance personnel, private fire brigade or fire departments to maintain, test and use private hydrants.

A construction permit is required for the installation or modification of private fire hydrants, Appendix chapter 1 Sec. 105.7.10 & Appendix "C" Fire Hydrant Locations and Distribution.

Additional
Requirements _____
Rev.01/09